

Bob Janes
District One

July 29, 2009
SOLICITATION NO.: **B-09-29**

A. Brian Bigelow
District Two

SUBJECT: ADDENDUM NUMBER ONE

Ray Judah
District Three

REFERENCE: **NORTH LEE COUNTY WTP OFFSITE PRODUCTION WELL
ACIDIZATION (PW-9, 10 and 18A)**

Tammy Hall
District Four

Frank Mann
District Five

The following changes shall become a part of the Bid Documents and shall be as binding as if contained therein:

Donald D. Stilwell
County Manager

CLARIFICATION

David M. Owen
County Attorney

1) Q: SECTION 190 DISINFECTION, PART 4 states "Payment for all work ... in this section ... will be at CONTRACTOR's unit price as stated in UNIT PRICE BID SCHEDULE." There is no item on the bid schedule for disinfection. How is this scope of work going to be paid for?


A: The cost for the required disinfection and 20-sample well clearance survey shall be included Bid Schedule Item A-1 Mobilization and Site Preparation. This activity is considered a component of the mobilization/demobilization activities.

2) Q: Also, Per SECTION 100, PART 2 – QUALIFICATIONS, 2.1 B. 1., will successful acidization of DEP-regulated Class I UIC injection wells be accepted in lieu of acidization of Municipal Water Supply Production Wells if the depths and diameters of the exceed the depths and diameters referenced?

A: Yes, successful acidization of DEP-regulated Class I UIC injection wells be accepted in lieu of acidization of Municipal Water Supply Production Wells if the depths and diameters of the exceed the depths and diameters referenced.

BIDDER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE BIDDING DOCUMENTS ARE AND SHALL REMAIN THE SAME.



Cindy S. Logan, Contracts Manager
Lee County Contracts Management